

REGISTER		REGISTRATION		REGISTRATION	
Company / Installer		Inspection/Installation Address		Landlord (or agent) Name & Address	
Engineer	Leyton Brooking	Name	Paul Davies	Name	Paul Davies
Company	Leyton Brooking	Address	Keble House, Moat Croft	Address	Keble House, Moat Croft
Address	3 Brinklow Croft, Birmingham, B34 7JQ		Birmingham		Birmingham
Tel No.	07455194476		West Midlands		West Midlands
Gas Safe Reg.	502963	Postcode	B37 5HD	Postcode	B37 5HD
ID Card No.	4199025	Mobile		Email	Paul.Davies@doddgroup.com
				Phone	

[illegible]

Defects Identified		Comments	
Defects	None	Comment	Attended site to carry out annual service of gas appliances.
Labels and Warning Notice Issued	No		Serviced appliances as per manufacturers instructions and
Defects	None		replaced electrodes, probes, seals and gaskets as per
Labels and Warning Notice Issued	No		manufacturers instructions. All annual service work completed.

Final Checks					
Cylinder/final connection hoses to LAV/boat Satisfactory	Gas Tightness Satisfactory	Gas Installation pipework visual inspection satisfactory	Equipotential Bonding	Gas Inlet working pressure at meter in mBars	Landlord Appliance
Yes	Yes	Yes	Yes	23.4	Yes

Signed		Received By		Date	14/12/2020
--------	---	-------------	---	------	------------

Print Name	Leyton Brooking	Print Name	Unoccupied	Next inspection Date	13/12/2021
------------	-----------------	------------	------------	----------------------	------------