

# Summary of Examinations

For Insp Dates: 17/03/2021

To: 17/03/2021

Unserviceable Items: 0

Owner: Solihull Metropolitan Borough Council

Remedial Items: 0

Site ID: Cheshunt House

Advisory Items: 2

Site: Cheshunt House

Serviceable Items: 0

Inspected By: Andrew Russell

Not Inspected Items: 0



Document ID: NOT169409

Our Reference: C42626

Generated: 18 March 2021

Building/Location	Item Description/YoM	User Ref	Manufacturer/Serial No.	SWL	Freq of Exam	Next Insp Date	Comment(s)	Client Ref 1	Priority
Even lift	Electric Passenger/Goods Lift - 9 floors, gearless, fire control (--)	9315031	Bennie / 9315031	8 person / 630 kg	6	17/09/2021	A - There is no visible smoke alarm present within the motor room - Advise to address	L0062	A
Odd lift	Electric Passenger/Goods Lift - 9 floors, gearless, fire control (--)	9315035	Bennie / 9315035	8 persons / 630 kg	6	17/09/2021	A - The trap door within the motor room has no safe working load marked - Advise to address	L0062	A