

Summary of Examinations

For Insp Dates: 02/02/2021

To: 02/02/2021

Owner: Solihull Metropolitan Borough Council

Site ID: Fircroft House

Site: Fircroft House

Inspected By: Andrew Russell

Unserviceable Items: 0

Remedial Items: 1

Advisory Items: 2

Serviceable Items: 0

Not Inspected Items: 0



DocumentID: NOT169394

Our Reference: C42611

Generated: 03 February 2021

Building/Location	Item Description/YoM	User Ref	Manufacturer/Serial No.	SWL	Freq of Exam	Next Insp Date	Comment(s)	Client Ref 1	Priority
LOBBY	ELECTRIC PASSENGER GOODS LIFT (11 Floors) (2016)	Odd lift	LES Refurb / 70845	600 kg / 8 Persons	6	02/08/2021	A - Suspension and safety gear ropes remain serviceable.	L0108	A
LOBBY	ELECTRIC PASSENGER GOODS LIFT (11 Floors) (2016)	Even lift	LES Refurb / 70846	600 kg / 8 Persons	6	02/08/2021	R120 - The doors closing speech, does not include the word 'closing' - Investigate and remedy A - Suspension and safety gear ropes remain serviceable.	L0108	R120, A