

# Summary of Examinations

For Insp Dates: 17/03/2021 To: 17/03/2021

Owner: Solihull Metropolitan Borough Council

Site ID: Kingsgate House

Site: Kingsgate House

Inspected By: Andrew Russell

Unserviceable Items: 0

Remedial Items: 2

Advisory Items: 0

Serviceable Items: 0

Not Inspected Items: 0



DocumentID: NOTI69410

Our Reference: C42627

Generated: 18 March 2021

Building/Location	Item Description/YoM	User Ref	Manufacturer/Serial No.	SWL	Freq of Exam	Next Insp Date	Comment(s)	Client Ref 1	Priority
Even Lift	Electric Passenger Lift - 11 floors (→)	70788	Lift & Engineering Services LTD / 70788	600kg / 8 Persons	6	17/09/2021	R60 - The E5 inspection carried out in February 2020 picked up an issue with the overload sensor assembly - Investigate if this has been remedied as no records show this has been addressed within the log cards.	L0126	R60
Odd lift	Electric Passenger Lift - 11 floors (→)	70787	Lift & Engineering Services LTD / 70787	600 kg / 8 Persons	6	17/09/2021	R60 - The E5 inspection carried out in February 2020 picked up an issue with the overload sensor assembly - Investigate if this has been remedied as no records show this has been addressed within the log cards.	L0126	R60