

Summary of Examinations

For Insp Dates: 22/02/2021

To: 22/02/2021

Owner: Solihull Metropolitan Borough Council

Site ID: Merton House

Site: Merton House

Inspected By: Andrew Russell

Unserviceable Items: 0

Remedial Items: 1

Advisory Items: 2

Serviceable Items: 0

Not Inspected Items: 0



DocumentID: NOT169401

Our Reference: C42618

Generated: 23 February 2021

Building/Location	Item Description/YoM	User Ref	Manufacturer/Serial No.	SWL	Freq of Exam	Next Insp Date	Comment(s)	Client Ref 1	Priority
EVEN LIFT	ELECTRIC PASSENGER / GOODS LIFT (10 Floors) (→)	EVEN LIFT	LES Refurb / 70784	600 kg / 8 Persons	6	22/08/2021	A - Suspension and safety gear rope remain serviceable.	L0067	A
ODD LIFT	ELECTRIC PASSENGER / GOODS LIFT (10 Floors) (→)	ODD LIFT	LES Refurb / 70783	600 kg / 8 Persons	6	22/08/2021	R30 - FIRST REPEAT - Car door open/close drive belt extremely perishing and delaminating - Replace A - Suspension and safety gear rope remain serviceable.	L0067	R30, A