

# Summary of Examinations

For Insp Dates: 19/03/2021 To: 19/03/2021

Owner: Solihull Metropolitan Borough Council

Site ID: Selwyn House

Site: Selwyn House

Inspected By: Andrew Russell

Unserviceable Items: 0

Remedial Items: 1

Advisory Items: 2

Serviceable Items: 0

Not Inspected Items: 0



DocumentID: NOT169407

Our Reference: C42624

Generated: 22 March 2021

Building/Location	Item Description/YoM	User Ref	Manufacturer/Serial No.	SWL	Freq of Exam	Next Insp Date	Comment(s)	Client Ref 1	Priority
Even lift	Electric Passenger/Goods Lift - 12 floors (--)	Even Lift	N/K / 70903	630 kg / 8 Persons	6	19/09/2021	<b>R30</b> - The in-car alarm connected to concierge but they could not hear the conversation- Remedy <b>A</b> - The firefighter function should be periodically tested and evidenced within the log card.	L0150	R30, A
Odd lift	Electric Passenger/Goods Lift - 12 floors (--)	Odd Lift	N/K / 70904	630 kg / 8 Persons	6	19/09/2021	<b>A</b> - The firefighter function should be periodically tested and evidenced within the log card.	L0150	A